

Ogunquit Fire Rescue

15 School Street, P.O. Box 875

Ogunquit, ME 03907

(207) 646-4947

08/19/2020

Ogunquit Planning Board

Dear Board Members,

In regards to the proposed Jon Moody / Pine Hill North Subdivision.

Please see the Fire departments requirements for the proposed project.

This project is outside of the town hydrant water supply, we would require the addition of a hydrant at the end of the proposed road, and the addition of a Hydrant on Pine Hill road at the entrance to the proposed road.

Last hydrant on Pine Hill Road is located 365 feet from the proposed road, hydrant tag number 5-39.

Sincerely

Robert E. Bernard, Jr. Captain
Fire Inspector, NFPA, CFI-1, CFPE
15 School St. P.O. Box 875
Ogunquit, ME 03907
(207) 646-4947